

# Attestation

## EU Taxonomy regulation

Emission of formaldehyde and carcinogenic compounds

On the 2<sup>nd</sup> of May 2025, Eurofins Product Testing A/S received a sample of a wood-based panel with the product name:

**Shinnoki panel**

**supplied by**

**Decospan NV**

The emissions were tested according to Regulation (EU) 2020/852 of the European Parliament and of the Council with regard to requirements for construction products on emission of formaldehyde and carcinogenic volatile organic compounds of section 7.1 (New buildings) and section 7.2 (Renovation of existing buildings).

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant EN 16516 (2020) testing standard (See test report no.392-2025-00136002\_A\_EN).

The emission result from the tested sample indicate that the product complies with the requirements of EU taxonomy regarding emission of formaldehyde and carcinogenic compounds.

**Evaluation of the emission test result according to EU Taxonomy:**

- The concentration of formaldehyde after 28 days was in compliance with the limit of  $\leq 0.06 \text{ mg/m}^3$ .
- Carcinogenic compounds were in compliance with the limit of  $0.001 \text{ mg/m}^3$ .

26 May 2025



Claus Bonde  
Analytical Service Manager



Rasmus Verdier  
Analytical Service Manager